

Power Systems of MS

14900 Tower Road
Vanceleave, MS 39565

Phone # 228-818-8315 Fax # 228-818-8317

Email: mark@powersystemsofms.net

Date	8/15/2024
Invoice #	10576

Bill To
Baldwin County 312 Courthouse Square Ste.12 Bay Minette, Alabama 36507 Attn: Wanda Gautney

Ship To
North End Area 100 Building

		Terms	Net 30	Project	
Serviced	Description	Quantity	Rate	Amount	
8/15/2024	Service call requested by Derrick due to lightning strike on building ATS and generator. When tech arrived he troubleshot unit and found bad generator controller, coolant sender, battery charger, ECM module, and EPA regulator. Parts Labor and Travel		0.00	0.00	
8/15/2024	Parts	1	20,222.00	20,222.00	
8/15/2024	Labor	28	100.00	2,800.00	
8/15/2024	Mileage	900	2.75	2,475.00	
			Sales Tax (7.0%)	\$0.00	
			Total	\$25,497.00	

A finance charge of 18% annual will be charged on all past due accounts.

Power Systems of MS

14900 Tower Road

Vanceleave, MS 39565

Phone: (228)-818-8315 Fax: (228)-818-8317

E-mail: mark@powersystemsofms.net

8/26/2024

Baldwin County

312 Courthouse Sq. Ste20

Bay Minette, AL. 36507

ATTN: Junius Long

RE: Area HWY Barn ATS


This will consist of removing damaged breaker due to lightning and installing new breaker and Impact 1500 Controller. Parts, Labor and Travel

COST: \$ 14,902.00

Should you have any questions, please contact me at 228-818-8315.

Thanks,

Accepted By:

A handwritten signature in black ink, appearing to read 'M Gotjen', with a long horizontal stroke extending to the right.

Mark Gotjen

Power Systems of MS